



Lawhon & Associates, Inc.

ENVIRONMENTAL CONSULTING AND ENGINEERING SERVICES

Columbus

Cleveland

Dayton

October 5, 2020

Mr. Tim Gehring
Director of Facilities Management
Worthington City School District
250 East Wilson Bridge Road
Worthington, Ohio 43085

**Re: Executive Summary Letter, *Legionella* Environmental Sampling
Facility: Bluffsview Elementary School
Sample Date: September 22, 2020
L&A Project No: 20-0441**

Dear Mr. Gehring,

Lawhon & Associates, Inc. (L&A) performed representative environmental sampling of the domestic water system servicing Bluffsview Elementary School. The testing was performed in accordance with guidance published by the Occupational Safety and Health Administration (OSHA) and the Centers for Disease Control (CDC) and the samples were submitted to a third party laboratory participating in the CDC *Legionella* Isolation Techniques Evaluation (Elite) Certification Program.

Legionella species were not detected at the representative domestic water outlets sampled. No further action is recommended.

Sincerely,

Karrie A. Bontrager, LEED AP
Principal and Sr. Microbiologist