



October 5, 2020

Mr. Tim Gehring  
Director of Facilities Management  
Worthington City School District  
250 East Wilson Bridge Road  
Worthington, Ohio 43085

**Re: Executive Summary Letter, *Legionella* Environmental Sampling**  
**Facility: Brookside Elementary School**  
**Sample Date: September 22, 2020**  
**L&A Project No: 20-0441**

Dear Mr. Gehring,

Lawhon & Associates, Inc. (L&A) performed representative environmental sampling of the domestic water system servicing Brookside Elementary School. The testing was performed in accordance with guidance published by the Occupational Safety and Health Administration (OSHA) and the Centers for Disease Control (CDC) and the samples were submitted to a third party laboratory participating in the CDC *Legionella* Isolation Techniques Evaluation (Elite) Certification Program.

*Legionella* species were not detected at the representative domestic water outlets sampled. No further action is recommended.

Sincerely,

Karrie A. Bontrager, LEED AP  
Principal and Sr. Microbiologist