



October 5, 2020

Mr. Tim Gehring  
Director of Facilities Management  
Worthington City School District  
250 East Wilson Bridge Road  
Worthington, Ohio 43085

**Re: Executive Summary Letter, *Legionella* Environmental Sampling  
Facility: Worthington Sutter Park PreSchool  
Sample Date: September 21, 2020  
L&A Project No: 20-0441**

Dear Mr. Gehring,

Lawhon & Associates, Inc. (L&A) performed representative environmental sampling of the domestic water system servicing Sutter Park PreSchool. The testing was performed in accordance with guidance published by the Occupational Safety and Health Administration (OSHA) and the Centers for Disease Control (CDC) and the samples were submitted to a third party laboratory participating in the CDC *Legionella* Isolation Techniques Evaluation (Elite) Certification Program.

The final analytical results indicate that *Legionella pneumophila*, which is responsible for more than 90% of Legionnaire's Disease cases, was not detected at any location. *Legionella anisa*, a species rarely associated with illness and widely distributed in water, was present in seven of the ten locations sampled, with four at or slightly above the OSHA guideline (10 CFU/ml); the percentage of samples that tested positive for *Legionella* (70%) was also above the guideline prescribed by CDC (30%). L&A recommends that the domestic water outlets in the building be flushed for a minimum of five minutes.

Sincerely,

Karrie A. Bontrager, LEED AP  
Principal and Sr. Microbiologist