



Lawhon & Associates, Inc.

ENVIRONMENTAL CONSULTING AND ENGINEERING SERVICES

Columbus

Cleveland

Dayton

October 5, 2020

Mr. Tim Gehring
Director of Facilities Management
Worthington City School District
250 East Wilson Bridge Road
Worthington, Ohio 43085

Re: Report of Findings for the *Legionella* Environmental Sampling
Facility: Colonial Hills Elementary School
Address: 5800 Greenwich St, Columbus, OH 43085
Sample Date: September 24, 2020
L&A Project No: 20-0441

Dear Mr. Gehring,

Lawhon & Associates, Inc. (L&A) performed environmental sampling to document concentrations of *Legionella* in the building's domestic water system. This testing was performed as a proactive measure to ensure *Legionella* concentrations are at acceptable levels following a period of reduced occupancy. L&A's conclusions and recommendations relevant to the sampling performed are presented in this document.

METHODOLOGY

L&A performed environmental sampling for *Legionella* at the site on September 24, 2020. Field activities included a visual assessment of conditions, documentation of water temperatures and the collection of representative water samples for analysis to document *Legionella* concentrations. All activities were performed in accordance with recommendations published by OSHA, AIHA, CDC and current infection control literature. The samples were sent cold, by overnight mail, to U.S. Micro-Solutions, Inc, Greensburg, Pennsylvania for analysis by culture method. This lab is certified to perform *Legionella* analysis through the Centers for Disease Control (CDC) Environmental *Legionella* Isolation Techniques Evaluation (Elite) Certification Program. U.S. Micro-Solutions, Inc. is also accredited by the American Industrial Hygiene Association (AIHA) through the Environmental Microbiology Proficiency Analytical Testing (EMPAT) Program.

FINDINGS

L&A collected ten (10) water samples from the domestic water system on this date. A summary of the analytical results is presented in Table 1. The comprehensive data set is presented in Appendix A. A copy of the laboratory report is included as Appendix B.

Table 1: Domestic Water Sampling Results

Location	Fixture	Water Source	Analytical Data (CFU/ml)
Boiler Room	Municipal Water Supply	Cold	ND
Boiler Room	Hot Water Tank	Hot	ND
Kitchen	Faucet	Hot	ND
Classroom 4	Faucet	Hot	ND
Corridor at RM15	Bottle Filling Station	Cold	ND
Boys Restroom	Faucet	Hot	46
Classroom 19	Faucet	Hot	2
Classroom 12	Faucet	Hot	ND
Boys Restroom near RM10/11	Faucet	Hot	5
Admin Lounge	Faucet	Hot	ND
<div><div>1. ND. <i>Legionella</i> species were not present above detection limits for the analytical method used.</div><div>2. OSHA recommends <i>Legionella</i> concentrations be maintained below 10 CFU/ml at domestic water outlets.</div></div>			

CONCLUSIONS

L&A conducted representative sampling of the domestic water system servicing Colonial Hills Elementary School. As illustrated in Table 1, analytical results indicate that *Legionella pneumophila*, which is responsible for more than 90% of Legionnaire's Disease cases, was not detected at any location. *Legionella feeleeii*, a species rarely associated with illness and widely distributed in water, was present in three of the ten locations sampled, with one slightly above the OSHA guideline (10 CFU/ml); the percentage of samples that tested positive for *Legionella* (30%) was at the upper limit prescribed by CDC (30%). L&A recommends that the domestic water outlets in the building be flushed for a minimum of five minutes.

CLOSURE

L&A has prepared this report for your use in accordance with generally accepted inspection and testing practices. The information obtained in this report is site and time specific and pertains to this project only. This inspection evaluated the conditions that were readily accessible at the time of the investigation of the subject property and does not warrant against hidden conditions or future alteration of conditions at the site, as well as subsequent changes in regulations. The opinions expressed in this report are based on L&A's experience, relevant literature and available information.

This report was prepared for the exclusive use of the Worthington City School District. No other party may rely on this report unless expressly designated by the Client in writing. The use of the report is subject to the limitations and exceptions set forth in this report, as well as the terms and conditions contained in the original contract documents. L&A will not distribute or publish this report without the Client's consent, except as required by law or court order.

Thank you for the opportunity to assist you in this important matter. If you have any questions concerning this report, please contact Karrie Bontrager at (614) 481-8600, extension 136.

Sincerely,

A handwritten signature in dark ink, appearing to read 'Karrie A. Bontrager', with a stylized, cursive script.

Karrie A. Bontrager, LEED AP
Principal and Sr. Microbiologist

APPENDIX A

Comprehensive Data Set

APPENDIX B
Laboratory Analytical Report



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com



Customer Name: Lawhon & Associates
Customer Address: 1441 King Avenue
Columbus, OH 43201
Customer Phone: (614) 481-8600
PO Number:
Project Name/Number: 20-0441 Worthington CSD - Colonial Hill Elementary School

Sample Date: September 24, 2020
Date Received: September 25, 2020
Date of Report: October 5, 2020
Fax: (614) 481-8610
Attention: Matt Geiger
Analysis Date: September 25, 2020
Sample Time: 0830
Analysis Time (hrs): 30.7

Customer sample numbers below are uniquely identified by prefixing Laboratory # 98161-20

Water/Liquid Sample(s) for *Legionella* Culture - Analytical Method MIC 06 MIC 07 (ISO 11731:2017)

Sample Number	Media	Sample Description	Results of Microbial Analysis
W-CHES-1	BCYE/GPCV	Boiler Room - Municipal Water Supply - Cold - First Draw	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			Not Detected
W-CHES-2	BCYE/GPCV	Boiler Room - Hot Water Tank - Hot - First Draw	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			Not Detected
W-CHES-3	BCYE/GPCV	Kitchen - Faucet - Hot - Flush	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			Not Detected
W-CHES-4	BCYE/GPCV	Classroom 4 - Faucet - Hot - Flush	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			Not Detected
W-CHES-5	BCYE/GPCV	Corridor at RM 15 - Bottle Filling Station - Cold - Flush	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			Not Detected
W-CHES-6	BCYE/GPCV	Boys Restroom - Faucet - Hot - Flush	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			Positive - 46 CFU/mL <i>Legionella feeleii</i>

Notes:

CFU/mL = colony forming units per milliliter, AS = analytical sensitivity.
Results are reported as Positive or Not Detected.

A negative culture for *Legionella* spp. from a sample does not necessarily rule out its presence.
Results relate only to the samples tested. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Sharon Danko

Sharon Danko, AS, MLT (ASCP)

Contact: Sharon Danko, Technical Manager: 724-853-4047



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com



Customer Name: Lawhon & Associates
Customer Address: 1441 King Avenue
Columbus, OH 43201
Customer Phone: (614) 481-8600
PO Number:
Project Name/Number: 20-0441 Worthington CSD - Colonial Hill Elementary School

Sample Date: September 24, 2020
Date Received: September 25, 2020
Date of Report: October 5, 2020
Fax: (614) 481-8610
Attention: Matt Geiger
Analysis Date: September 25, 2020
Sample Time: 0830
Analysis Time (hrs): 30.7

Customer sample numbers below are uniquely identified by prefixing Laboratory # 98161-20

Water/Liquid Sample(s) for *Legionella* Culture - Analytical Method MIC 06 MIC 07 (ISO 11731:2017)

Sample Number	Media	Sample Description	Results of Microbial Analysis
W-CHES-7	BCYE/GPCV	Classroom 19 - Faucet - Hot - First Draw	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			Positive - 2 CFU/mL <i>Legionella feeleyi</i>
W-CHES-8	BCYE/GPCV	Classroom 12 - Faucet - Hot - Flush	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			Not Detected
W-CHES-9	BCYE/GPCV	Boys Restroom near RM10/11 - Faucet - Hot - Flush	
AS = 5 CFU/mL (Volume examined: 100 mL)			Positive - 5 CFU/mL <i>Legionella feeleyi</i>
W-CHES-10	BCYE/GPCV	Admin Lounge - Faucet - Hot - Flush	
AS = 0.5 CFU/mL (Volume examined: 100 mL)			Not Detected

Notes:

CFU/mL = colony forming units per milliliter, AS = analytical sensitivity.
Results are reported as Positive or Not Detected.

A negative culture for *Legionella* spp. from a sample does not necessarily rule out its presence.
Results relate only to the samples tested. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Sharon Danko

Sharon Danko, AS, MLT (ASCP)


Contact: Sharon Danko, Technical Manager: 724-853-4047

End of Report



U.S. Micro-Solutions, Inc.

302 Unity Plaza
Latrobe, PA 15650
P: 724-853-4047 F: 724-853-4049
supplies@usmslab.com



NY ELAP #12055
The New York Environmental
Laboratory Approval Program

LEGIONELLA / WATER TEST REQUEST - CHAIN OF CUSTODY

CUSTOMER NAME: Lawhon & Associates		PHONE #: 614-481-8600		FAX #: 614-481-8610	
ADDRESS: 1441 King Avenue		CITY: Columbus		STATE: Ohio ZIP: 43201	
ATTENTION TO: Karrie Bontrager & Matt Geiger		E-MAIL: kbontrager@lawhon-assoc.com & mgeiger@			
SAMPLE OBTAINED BY: Matt Geiger		RESULTS:	<input checked="" type="checkbox"/> FAX	<input checked="" type="checkbox"/> EMAIL	
PROJECT NAME/NUMBER: 20-0441 Worthington CSD - Colonial Hill Elementary School		PO#			
# SAMPLES: 10		Samples collected in New York state? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
SAMPLE NUMBER	SAMPLE DATE / TIME	SAMPLE LOCATION AND DESCRIPTION			
W-CHES-1	9/24/2020 8:30am-10:30am	Boiler Room - Municipal Water Supply - Cold - First Draw			
W-CHES-2	9/24/2020 8:30am-10:30am	Boiler Room - Hot Water Tank - Hot - First Draw			
W-CHES-3	9/24/2020 8:30am-10:30am	Kitchen - Faucet - Hot - Flush			
W-CHES-4	9/24/2020 8:30am-10:30am	Classroom 4 - Faucet - Hot - Flush			
W-CHES-5	9/24/2020 8:30am-10:30am	Corridor at RM15 - Bottle Filling Station - Cold - Flush			
W-CHES-6	9/24/2020 8:30am-10:30am	Boys Restroom - Faucet - Hot - Flush			
W-CHES-7	9/24/2020 8:30am-10:30am	Classroom 19 - Faucet - Hot - First Draw			
W-CHES-8	9/24/2020 8:30am-10:30am	Classroom 12 - Faucet - Hot - Flush			
W-CHES-9	9/24/2020 8:30am-10:30am	Boys Restroom near RM10/11 - Faucet - Hot - Flush			
RELINQUISHED BY - CUSTOMER (MUST SIGN)		DATE AND TIME			Analyst Initials
[Signature]		9/24/2020 @ 4:00pm			
RECEIVED BY - LAB USE ONLY		DATE AND TIME			LABORATORY NUMBER
[Signature]		09/25/2020 1045			98161-20



supplies@usmslab.com

