Columbus

Cleveland

Dayton

October 5, 2020

Mr. Tim Gehring Director of Facilities Management Worthington City School District 250 East Wilson Bridge Road Worthington, Ohio 43085

Re: Executive Summary Letter, Legionella Environmental Sampling

**Facility: Worthington Park Elementary School** 

Sample Date: September 24, 2020

**L&A Project No: 20-0441** 

Dear Mr. Gehring,

Lawhon & Associates, Inc. (L&A) performed representative environmental sampling of the domestic water system servicing Worthington Park Elementary School. The testing was performed in accordance with guidance published by the Occupational Safety and Health Administration (OSHA) and the Centers for Disease Control (CDC) and the samples were submitted to a third party laboratory participating in the CDC *Legionella* Isolation Techniques Evaluation (Elite) Certification Program.

Legionella species were not detected at the representative domestic water outlets sampled. No further action is recommended.

Sincerely,

Karrie A. Bontrager, LEED AP Principal and Sr. Microbiologist

1441 King Avenue | Columbus, Ohio 43212 | P: 614.481.8600 | F: 614.481.8610 | www.lawhon-assoc.com