Summary of Legionella Testing Results and Associated Corrective Actions

Building	Results	Corrective Action	Status
Bluffsview Elementary	No Legionella detected	None	NA
Brookside Elementary	No <i>Legionella</i> detected	None	NA
Granby Elementary	No <i>Legionella</i> detected	None	NA
Linworth Alternative	No Legionella detected	None	NA
McCord Middle School	No Legionella detected	None	NA
Phoenix Middle School	No Legionella detected	None	NA
Wilson Hill Elementary	No Legionella detected	None	NA
Worthington Park	No Legionella detected	None	NA
Colonial Hills Elementary	Low levels of Legionella	Flush Outlets as Precautionary Measure	Complete
Kilbourne High School	Low levels of Legionella	Flush Outlets as Precautionary Measure	Complete
Slate Hill Elementary	Low levels of Legionella	Flush Outlets as Precautionary Measure	Complete
Sutter Park Preschool	Low levels of Legionella	Flush Outlets as Precautionary Measure	Complete
Worthington Estates	Low levels of Legionella	Flush Outlets as Precautionary Measure	Complete
Thomas Worthington High School	Low levels of Legionella	Flush Outlets as Precautionary Measure	Complete
Worthingway Middle School	Low levels of Legionella	Flush Outlets as Precautionary Measure	Complete
Evening Street Elementary	Actionable levels of Legionella	Superheat and Flush	Complete
Kilbourne Middle School	Actionable levels of Legionella	Superheat and Flush	Complete
Worthington Hills Elementary	Actionable levels of Legionella	Superheat and Flush	Complete
Liberty Elementary	Actionable levels of Legionella	Chlorinate and Flush	Complete

